10:30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 144505 PIN# 4627750643 Cell DATE 8/31/07

OWNER OR APPLICANT Cathy Peacock PHONE: Business 201-1326 Home 537-5748

ADDRESS 8044 Southway Rd Charlotte, NC 28215

LOCATION Hwy 150 W. TL Paradise Peninsula Rd TL Greenbay Rd TR Hogan Ln near end on right

SUBDIVISION Cluff BLOCK / SECTION 10 LOT 142 LOT AREA .58 Acre SITE CLASS. PS DESIGN FLOW 360 gpd L.T.A.R. .35

Septic Tank: 1000 Gallons: STB 312 Date 9-12-08

Pump Tank: 1000 Gallons: PT 27 Date 7-19-05

Pump Make Gould's Model WE0312MV Serial No.

Nitrification Field: No Fields 1 Square Feet 360' Linear Feet 180'

No Lines 4 Trench Width min 24" Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: Pump-LP-Panel BIK

Repair System Description: TS-II Pretreatment Dsp

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons ___ No. Employees ___

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Initial site evaluation & system design performed by SAME

Comments:/Conditions: 3/16" hole drilled, 40 panels 11/6/08 Checked tanks & pressure

INITIAL SITE SKETCH

See approved plan (attached) by Patrick Mitchell w/ SAME

AS BUILT SKETCH

11/26/08 Set 2ft pressure Elect & Alarm

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Cathy D. Peacock date

Improvement Permit by: Maria H. Dotson RS date 8/31/07

Authorization to Construct by: Maria H. Dotson RS date 9/11/07

Installed by: R&H date

Operation Permit by: Maria H. Dotson date 11/26/08

Existing System Inspection by: ___ date ___

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK