IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jim Carpenter DATE 7-1-74 PERMIT NO. 174

PHONE: Business _____ Home _____

LOCATION 150 West TL on 1211 Stay left on 1218 Imi TR 600' on left S. R. No. 1218


SUBDIVISION NAME Lake Norman LOT NO. 136 SECTION OR BLOCK NO. 10

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area over ½ acre

Character & Porosity of Soil Fine Sandy clay loam Porosity fair
Percolation Rate Not taken
Topography 2 to 3% Slope
Depth to Water Table 8 to 10' to lake level
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10
Water Supply: Individual (✓)
Public ( )
Getting water from next door

Installed by Sam Oswalt

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Mobile Home was not on lot at time of this inspection

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-1-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold