IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 203243

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4627 774 794

APPLICANT: Western Carolina Holdings APPLICANT ADDRESS: 201 E Main St Lincolnton, NC

SITE ADDRESS: 256 Greenbay Rd Mooresville NC PHONE: ALT. PHONE:

SITE DIRECTIONS: Hwy 150 W to L Paradise Peninsula Rd TL Greenbay Rd TR Newark Ln on R

SUBDIVISION: Lot 1 SECTION: 10 LOT # 158 LOT AREA: DESIGN FLOW: 360 gpd L.T.A.R.: .35

Septic Tank 1000g (gal) STB 1012 Date 9-4-13 ☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

Pump Tank 1000g (gal) PT 17 Date 3-17-14 System Description: LPPPBPS

Pump Make Myers Model ME50S Serial # 1003623 Repair System Description: Same

Nitrification Fields 1 # Lines 4 Linear Ft. 176' Maintenance Agreement Required: ☒ YES ☐ NO

Trench Width Min. 24" Max. Trench Bottom Depth 30-36" Gravel Depth N/A ☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 3 ☐ Business No. Persons 6 ☐ Other No. Employees ☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: * 176ft (per design)

3 1/2" hole drilled (41 panels) 217 pressure set. SST PT & drain lines ~~set~~ inspected MJ Maint. agreement attached

INITIAL SITE SKETCH

See approved plan by Kathleen Saunders LSS (dated 5-6-14)

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

IMPROVEMENT PERMIT with plat valid without expiration. ☒ IMPROVEMENT PERMIT with site plan valid for 60 mos. ☐ AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: Kathleen Saunders Date: 5-21-14 Installed by: Steve Jordan

IMPROVEMENT PERMIT by: Maria Dotson RS Date: 5/20/14 OPERATION PERMIT by: Maria Dotson RS Date: 6/30/14

AUTHORIZATION TO CONSTRUCT by: Maria Dotson Date: 5/21/14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK