664-6509

IREDELL COUNTY HEALTH DEPARTMENT

1064 1

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Harold Finlon DATE Jan. 16, '90 PERMIT NO. 2L-6-A-159

PHONE: Business _____ Home _____

LOCATION 150 W TR 1211 (Paradise Rd.) Bear left on 1218 (Greenbay) ½-1 mile on Right S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 1141 SECTION OR BLOCK NO. 10

Future Temp

House (✓) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site ~~Suitable~~ PS Yes (✓) No ( )

Character & Porosity of Soil Sandy clay
Percolation Rate 20.35
Topography 15% Complex
Depth to Water Table 4'+
Rock or other impervious formations none obs

Lot Area 1.05 AC

_____ Basement with Plumbing _____ Basement without Plumbing ___/___ No Basement



Plot of System

Size of Tank 1000 p.T. / 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. _____ Linear Ft. 180'
Depth of Stone in Lines 16" ~~12~~
Water Supply: Individual (✓) panels
Public ( ) pvt.

Installed by Ray Bear

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Greenbay Rd

IMPROVEMENTS PERMIT BY _____

COMMENTS: Alarm tested & working, but not mounted (Mt not on lot yet)

CERTIFICATE OF COMPLETION BY _____ DATE Jan 16, '90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

