DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: DUANE LEWIS (MITCH VENABLE) APPLICANT: DAVID R WHITMAN
ADDRESS: _____ APPLICATION DATE: 7/21/00 DATE EVALUATED: 8/8/00
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ~.75 SURVEYED
LOCATION OF SITE: CL+T Sec 10 Lot 212 Paradise Peninsula Rd. PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	3%	0-5	SBK / cl	FR SP SS	S		u		
		6-18	AB / C SAP	FI S - P	PS				
		19-27	SBK / cl SAP	FR S - SP	u				
		27-41	SBK / l SAP	FI SS - NP	PS			42	u
		42	Rock						
2	8/29/00 PIT	0-6	LG SBK / cl	FI SP SS					
		7-14	SBR / cl SAP	FR SS SP					.25
		15-22	GR / l SAP	FR NS NP					
		23-39	FI IN SIT / GR / l SAP	FR NS NP					
		39-60	NFI / GR / SAP	FI NS NP					
3	8/29/00 PIT				40" TR				
4					① AVAILABLE SPACE ② EXISTING WELL				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	u	NONE
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): SPACE LIMITATIONS-VERY TIGHT
SITE CLASSIFICATION (.1948): u
EVALUATED BY: Sparks
OTHER(S) PRESENT: D Lewis