IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR E. C. Cavin DATE 10-9-74 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION 1100 TR on 1178 1mi TL on 1143 2mi TL on 1144 (Beaton Path) 1½mi on right S. R. No. 1144

SUBDIVISION NAME Lake Norman LOT NO. 29 17 SECTION OR BLOCK NO. 9

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Existing	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate		
Auto. Wash. Machine	Yes (✓)	No ( )	Topography		
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	System	
Lot Area 3/4 acre			Rock or other impervious formations		



Plot of System Road

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Sam Oswalt
9-17-73
Permit No. 231

IMPROVEMENTS PERMIT BY _____

COMMENTS: System was Functioning properly as of 10-9-74

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-9-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold