# IREDELL COUNTY HEALTH DEPARTMENT

Roberta Inez Kraus 11:30-12:00

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 178322

## IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4627804586

APPLICANT: STEPHEN & NANCY JAMGOCHIAN APPLICANT ADDRESS: 8432 TIMBERLANE TERRELL NC 28682

SITE ADDRESS: 691 BEATEN PATH - MOORESVILLE 28117 PHONE: ALT. PHONE: 578 5175

SITE DIRECTIONS: BRAWLEY SCHOOL - TR BLUME - TL BEATEN PATH - ON LT

SUBDIVISION: SHAVENDER'S BLUFF SECTION: LOT # 65 LOT AREA: .73 AC DESIGN FLOW: 480 L.T.A.R.: .36 PD/PT 2

Septic Tank 1000 (gal) STB 794 Date 10-3-13

Pump Tank 1000 (gal) PT 283 Date 10-8-13

Pump Make Goulds Model VEO3121 Serial # 275

# Nitrification Fields 1 # Lines 4 Linear Ft: ~~400~~

Trench Width ~~30~~ 36" Max. Trench Bottom Depth 30" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LPPBPS

Repair System Description: SAME

Maintenance Agreement Required: ☑ YES ☐ NO ☐ GRAVITY ☑ PRESSURE

☑ Residence No. Bedrooms 4

☐ Business No. Persons 8

☐ Other No. Employees

☐ Slab ☑ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions:

* 3/16 Hole Size, Tanks & Lines Checked 11-19-13 ALP
11/19/13 Set 2ft pressure
4 inches 2 min.; 2 inches per minute
Used in line filter in PT

INITIAL SITE SKETCH

SEE ROLANS SOIL & ENVIRONMENTAL SERVICES. PLAN

AS BUILT SKETCH

*Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.* **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Nancy Jamgochian Date: 4/26/13 Installed by: Stanley Environmental

IMPROVEMENT PERMIT by: Date: 4/26/13 OPERATION PERMIT by: RS Date: 11/20/13

AUTHORIZATION TO CONSTRUCT by: Date: 5/14/13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (final Approval) - YELLOW Applicant (Conditional Approval) - PINK