IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John T. Mosley DATE 5-21-25 PERMIT NO. 94

PHONE: Business 223-4175 Home

LOCATION 220 Iron Horse Trl, Troutman, NC 28166 Turn right off

Hwy 21 S. R. No.

SUBDIVISION NAME Iron Horse LOT NO. 46 SECTION OR BLOCK NO. 2


House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay Loam
Percolation Rate 45 min/inch
Topography Slight slope to the front
Depth to Water Table 40 inches
Rock or other impervious formations None

Lot Area 5 acres



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 450 Linear Ft. 300
Depth of Stone in Lines 24"
Water Supply: Individual (✓)
Public ( )

Installed by Lowe Bros.

IMPROVEMENTS PERMIT BY

COMMENTS:

CERTIFICATE OF COMPLETION BY Walter Thompson DATE 5-21-25

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold