DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Craig Pelchat — APPLICANT: _____
ADDRESS: 714 Beaton Park Rd — APPLICATION DATE: 12/9/03 — DATE EVALUATED: 1/12/04
PROPOSED FACILITY: House — PROPOSED DESIGN FLOW (.1949): 360 — PROPERTY SIZE: _____
LOCATION OF SITE: Beaton Park Rd. Sec 9 Lot 19 — PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	5% CVL	0-8	GR / sl	VFR - NS - NP	S / R				
		8-30	sBK / c	FI S - SP	PS / R				
		31-48	M sBK / cl SAP	FR SS - SP	PS / R-YR				.3
2	4% MCCL	0-13	sBK / c	FI S - SP	S / RD				
		14-31	sBK cl	FR SS - SP	PS / R				
		FLOAT Rocks							.3
3	5% L	0-7	GR / cl	FI S - SP	S / BR				
		8-29	sBK / c	FR SS - SP	PS / R				
		30-48	M sBK / cl SAP	FR SS - SP	PS / R-YR INCL				.3
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	< 1983
System Type(s)	PM - EZLAY	PPBPS
Site LTAR	.3	

OTHER FACTORS (.1946): Abandon well 2" / New well
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Adams
OTHER(S) PRESENT: Craig, Jeff Pelchat