4627835009

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Randy B. Thomas DATE 3-26-86 PERMIT NO. 148

PHONE: Business _____ Home _____

LOCATION 1100 TR on Blume Rd TL on Beaten Path 2 mile on Rt. S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 61 SECTION OR BLOCK NO. 9


House ( ) Mobile Home ( ) Business ( ) Other Adding Bedroom

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loom
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	15
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2+10%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	over 4' to lake level
			Rock or other impervious formations	none

Lot Area 20,000 SF

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank Existing Gals.

Nitrification Field: (Addition)
No. of Lines 2
Sq. Ft. 488 Linear Ft. 130
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by AAA Enterprises

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Charles Barnett amended from 3-25-86

COMMENTS: _____

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 3-26-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold