IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Claude O. Plott II DATE 7-31-80 PERMIT NO. 239

PHONE: Business _____ Home _____

LOCATION 1100 TR 1178 TL 1443 Bear left on Dogwood Loop 2nd on left

SUBDIVISION NAME LAKE NORMAN LOT NO. 77 SECTION OR BLOCK NO. 9 S. R. No. _____

House (X) Mobile Home (X) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	
Auto. Dishwasher	Yes ( )	No (X)	
Auto. Wash. Machine	Yes (X)	No ( )	
Site Suitable	Yes (X)	No ( )	

Lot Area .70 ACRE

Character & Porosity of Soil Sandy loam w/Rock
Percolation Rate Not done
Topography 2-40%
Depth to Water Table 10'+
Rock or other impervious formations Rock outcroppings

_____ Basement with Plumbing X Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (X)
Public ( )

installed 6-20-75 by Former Owner
Installed by OWNER

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Existing system working OK at date of inspection (7-31-80) System originally designed for Jr. Dillard (Vans John) inspected 6-20-75 by John Houston (permit # 132) - Remove MH before Final Power Approval

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Fred Clemmer DATE 7-31-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold