9628478472

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gray Ellis DATE 11-15-95 PERMIT NO. 246

PHONE: Business 704-528-[illegible] Home 395-5444

LOCATION 1100 TR on 1178 Then Turn thru
work Drive Go to Rear Round Loop S. R. No.

SUBDIVISION NAME Lake Norman LOT NO. 89 SECTION OR BLOCK NO. 9


House ( ) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Sandy clay Loam/gravel
Percolation Rate 30" 1 Fall Lowest
Topography 2 to 20% Slope
Depth to Water Table 4'+
Rock or other impervious formations none

Lot Area 2 Acres

owner wants 2 compt. septic tank



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 415 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by

IMPROVEMENTS PERMIT BY L. C. Mayo

COMMENTS:

CERTIFICATE OF COMPLETION BY DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold