IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR B. H. Canaan DATE 6-5-75 PERMIT NO. 114

PHONE: Business _____ Home 364-4605

LOCATION 1100 TR on 1178 TL on 1443 on left on Dogwood Loop S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 79 SECTION OR BLOCK NO. 9


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ½ acre

Character & Porosity of Soil Sandy Clayloam Porous Fair
Percolation Rate Not Taken
Topography 5% Slope
Depth to Water Table 8
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 600 Linear Ft. 250
Depth of Stone in Lines 10
Water Supply: Individual (✓)
Public ( )

Installed by E. J. Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 6-3-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold