4627850299

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

CONTRACTOR Rick Thomes DATE 3-2-82 PERMIT NO. 34

Business _____ Home _____

LOCATION 1600 TR 1178 TL 1443 (Dogwood Drive) PASS
Eaten Path Store on 1443 ON left before 1443 loops around

SUBDIVISION NAME Lake Norman LOT NO. 80 SECTION OR BLOCK NO. 9 S. R. No. _____

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)
Auto. Dishwasher	Yes (X)	No ( )
Auto. Wash. Machine	Yes (X)	No ( )
Site Suitable	Yes (X)	No ( )

Lot Area ~ ¾ Acre

Character & Porosity of Soil Existing System
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____

~~Basement with Plumbing~~ _____ Basement without Plumbing _____ X No Basement



Size of Tank Existing 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (X)
Public ( )
well next door
3-8-74
Installed by J. J. Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Checked by TC Moore 3-8-74

IMPROVEMENTS PERMIT BY J. Doug Gabriel

COMMENTS: Existing system working okay at date of inspection
Owner must remove Mobile Home from septic system
before final building inspection approval

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Fred Clemmer DATE 3-2-82

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold