IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Carl C. Crotzer DATE 10-6-77 PERMIT NO. _____

PHONE: Business _____ Home 875-2290


LOCATION 150w TR on 1211 TL on 1218 TL on 1218 1mi on right S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 225 SECTION OR BLOCK NO. 10

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area .67

Character & Porosity of Soil Rocky Material Sandy
Percolation Rate 2 60 min per
Topography 22% Slope
Depth to Water Table 70"
Rock or other impervious formations Some Rock



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )
Well Not Near
Installed by E.S. Erwin

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 12-6-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold