IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 50.00 Paid MOORESVILLE 704-664-5281 4.00

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 88637 PIN# ~~4627817014~~ 4027913436 DATE 2/22/01

OWNER OR CONTRACTOR SHAVENDER'S DEV/ DUPONT PHONE: Business 660-0402 Home

ADDRESS 117 SYCAMORE SLOPE LN MOORESVILLE

LOCATION BRAWLEY SCHOOL - TR BLUME - TL BEATEN PATH - TL CICERO - TL SHAVENDERS DRIVE - ON RT

SUBDIVISION SHAVENDER'S BLUFF BLOCK / SECTION LOT 101 LOT AREA - SITE CLASS. PS DESIGN FLOW 360 GPD L.T.A.R. .30 AD/FT2

Septic Tank: 1000 Gallons; STB 1012 Date 11-27-00

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 4 @ 100' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: GRAVITY CONVENTIONAL

Repair System Description: LP CAP EL

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 3

☐ Business No. Employees

☐ Other

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Public ☐ Community

Comments:/Conditions:

1"=40'

215'

INITIAL SITE SKETCH

Old Rd Bed

REPAIR

DRIP LINES

HOUSE

65'

65'

80'

35'

65'

DRIVE

4 @ 100'

REPAIR

20-25' to R

325'

Comments:/Conditions:

(REVISED)

AS BUILT SKETCH

SEE "AS BUILT DRAWING"

DUKE POWER R/W

180'

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit - not to exceed sixty months.

Signed: date 2/26/2001 Installed by: Richard Abernathy

Improvement Permit by: date 2/22/01 Operation Permit by: Maria H. Dotson R.S date 4/23/2001

Authorization to Construct by: date 2/22/01 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK