IREDELL COUNTY HEALTH DEPARTMENT 4627-91-8945

1141

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Daniel J. Hagberg DATE June 27, '90 PERMIT NO. 2L-A21

PHONE: Business _____ Home _____

LOCATION 1100 TR 1178 (Blume) TR 1443 a 1/2 - 3/4 mile on Right

S. R. No. _____

SUBDIVISION NAME CLOT LAKE NORMAN LOT NO. 21 SECTION OR BLOCK NO. 9

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site ~~Suitable~~ B Yes (✓) No ( )
Lot Area EXISTING

Character & Porosity of Soil clay loam
Percolation Rate .25
Topography 6-15%
Depth to Water Table 44
Rock or other impervious formations some scattered rock

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement

1250 P.T.



Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. _____ Linear Ft. 240
Depth of Stone in Lines 16" 175 per

Water Supply: Individual (✓)
Public ( )

Installed by H J Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY SCI

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Henson, EHS DATE June 27, '90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold