IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 072384 PIN# 4627923300 DATE 3/12/98

OWNER OR CONTRACTOR SHAVENDERS DEV. GROUP PHONE: Business 663-6905- T JACOBS Home

ADDRESS 1143-D EXECUTIVE CIRCLE - CARY NC 27511

LOCATION BRAWLEY SCHOOL RD - TR BLUME - TL BEATEN PATH - TL DOBBEN - 2nd ON LT

SUBDIVISION SHAVENDERS BLUFF BLOCK / SECTION 2 LOT 301 LOT AREA 3.974C SITE CLASS. PS DESIGN FLOW 1370GAD L.T.A.R. .35gal/ft²

Septic Tank: ~~2000~~ Gallons; STB 7 Date 5/11/98

Pump Tank: ~~2000~~ Gallons; PT 7 Date 4/24/98

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 3426 Linear Feet 1142

No Lines 9 Trench Width 36" Max Trench Bottom Depth 36"

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: PUMP CHAMBERED

Repair System Description: SAME

Maintenance Agreement Required: ☑ Yes ☐ No

☐ House/Mod. Home No. Bedrooms ____

☐ Mobile Home No. Bathrooms ____

☐ Business No. Employees ____

☑ Other POOL & CABANA

Gravel Depth N/A ☑ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Public ☐ Community

Comments:/Conditions:

Pump #1 - 1 HP WE 101 2H - #98299111 > GRINDS

Pump #2 - 1 HP WE 101 2H - #98426001 >

Comments:/Conditions:

3000 GAL TANKS INSTALLED

INITIAL SITE SKETCH

SEE TONEY JACOBS & ASSOCIATES, INC. AMENITY AREA SEPTIC DESIGN.

AS BUILT SKETCH

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 3-16-98 Installed by: FJ ERWIN

Improvement Permit by: C. [signature] RS date 3/12/98 Operation Permit by: C. [signature] date 4/8/99

Authorization to Construct by: C. [signature] RS date 3/12/98 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD