EDELL COUNTY HEALTH DEPARTMENT

ANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

CONTRACTOR T. C. Cook Tr. DATE 7-25-96 PERMIT NO. _____

ON: Business _____ Home _____

LOCATION Hwy 18 TR on 1178 TL on 1443 1m

S. R. No. 1443

SUBDIVISION NAME Uohe Norman LOT NO. 100 SECTION OR BLOCK NO. 2

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Apo. Dishwasher Yes ( ) No (✓)

Apo. Wash. Machine Yes (✓) No ( )

Sit. Suitable Yes (✓) No ( )

Lot Area 5+ acres

Character & Porosity of Soil Sandy clay loam / Sandy clay


Percolation Rate Soil Bored 5 Slots

Topography 2-20% slopes

Depth to Water Table 10'

Rock or other impervious formations 7-20"

Lake, Ditch, 4x125' lines



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 625 Linear Ft. 500

Depth of Stone in Lines 24"

Water Supply: Individual (✓)

Public ( )

Installed by T. C. Cook

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 7-25-96

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold