4627940077

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Barry Kline DATE 7-28-00 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hor TR on 1178 TL on 1443 Im on right S. R. No. 1443

SUBDIVISION NAME Lake Norman LOT NO. 95 SECTION OR BLOCK NO. 9

Residence (Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area Acre


Character & Porosity of Soil Clay loam Porosity Fair

Percolation Rate Soil borings

Topography 20a slope

Depth to Water Table 6 to 8' ± to lake level

Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS Place well up slope + 100' from any part of septic Tank System.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 9-25-00

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Kline DATE 2-23-94 PERMIT NO. 285

PHONE: Business _____ Home _____

LOCATION [illegible]

S. R. No. _____

SUBDIVISION NAME [illegible] LOT NO. 15 SECTION OR BLOCK NO. 7

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area [illegible]


Character & Porosity of Soil Cullasaja gravelly fine

Percolation Rate 30 1 Inch

Topography Slope

Depth to Water Table 60+ [illegible]

Rock or other impervious formations None



Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 450 Linear Ft. 150

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold