DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____OF_____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Stuart Schafer OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 12/6/93
PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS	0-3"	gr / SL	1:1 / vfr	—	—	PS	—	e6
		3-24"	sbk / C	1:1 / fi-sticky slpl	—	—	PS	—	.4
		24-46"	wk sbk / sicl	1:1 / fr slpl	—	—	PS	—	e3
2									
3									
4									
5									

AVAILABLE SPACE (.1945)_____ SITE CLASSIFICATION (.1948):_____ SITE LONG-TERM ACCEPTANCE RATE: .3

EVALUATED BY:_____ OTHER(S) PRESENT:_____

COMMENTS:_____