4627962166

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas Simpson DATE Oct. 6, '78 PERMIT NO. 251

PHONE: Business _____ Home _____

LOCATION 150 W T.L. on 1211 T.L. on 1219 T.L. on 1218 ~ 1 mi. on Rt

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. 108 SECTION OR BLOCK NO. 10


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area ~ 3/4 Ac.

Character & Porosity of Soil Clay loam
Percolation Rate _____
Topography Level
Depth to Water Table unk.
Rock or other impervious formations some scattered rock



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16" +
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Ervin Const. Co.

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE Oct. 6, '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold