4627963078

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John I. Lowery DATE 12-8-50 PERMIT NO. 362

PHONE: Business _____ Home _____

LOCATION 150 W pass Zuni TL 1211, Bear left on 1219 abt 2.5 Mile bnR - Look for haggrock TR Rock 2nd MH S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 107 SECTION OR BLOCK NO. 10

House ( ) Mobile Home (X) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)
Auto. Dishwasher	Yes (X)	No ( )
Auto. Wash. Machine	Yes (X)	No ( )
Site Suitable	Yes (X)	No ( )

Lot Area 0.97 Acre

Character & Porosity of Soil _____
Percolation Rate Existing
Topography _____
Depth to Water Table System
Rock or other impervious formations _____

_____ Basement with Plumbing (X) Basement without Plumbing X No Basement



Plot of System

Existing
Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 320 Linear Ft. 225
Depth of Stone in Lines 10"
Water Supply: Individual (X)
Public ( )
Has from Next door well
Installed by J.R Bowles 4-14-72

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Operating System Checked by J.C. Moore 4-14-72

IMPROVEMENTS PERMIT BY J.C Moore

COMMENTS: Existing System working OK at Date of inspection

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Fred Clemmer DATE 12-8-50

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold