IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 $375.00 Paid MOORESVILLE 704-664-5281 2-2130

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 122959 PIN# 4628423249 Norma (Agent) DATE 8-19-04

OWNER OR CONTRACTOR John O'Neill / Stephen Hartsell PHONE: Business 500-3009 Home 703 926-8248

ADDRESS 154 Montibello Dr Mooresville, NC

LOCATION Hwy 150 West TR Pinnacle Ln on right in Cul-de-sac

SUBDIVISION Pinnacle Shores BLOCK / SECTION III LOT 36 LOT AREA .72 Acre SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 1060 Date B10521700414

Pump Tank: 1000 Gallons; PT 1060 Date B10927770

Pump Make: Zoeller Model E161 Serial No.

Nitrification Field: No Fields 1 Square Feet Linear Feet 280'

No Lines 4 @ 70' Trench Width 24"-36" Max Trench Bottom Depth 30" Gravel Depth

☒ New System ☐ Repair System Type: I, II, III, (IV), V, VI

System Description: Pump-LP-Panel Block

Repair System Description: Same

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms 4

☐ Business No. Employees

☐ Other

☐ Slab ☒ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions:

Keep Septic System at least 50' From lake & 10' From PL.

*Keep drainfield 25' From basement.

Central Gate Valve Box PL 197'

Comments:/Conditions:

* Inline Filter in PT partial

10/28/08 Checked tanks, 10/31/08 Checked Drainfield

INITIAL SITE SKETCH

Repair Area

Crawl

House 60'x60'

Basement

Drive

PL 133'

PL 413'

PL

Pinnacle Lane

AS BUILT SKETCH

11/21/08 Checked Pressure 2PSI Alarm

Lake Norman

50'

PT

ST

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit, not to exceed sixty months.

Signed: John O'Neill date 9-15-04

Improvement Permit by: Maria Watson R.S. date 8/19/04

Authorization to Construct by: Wesley Sparks R.S. date 1/23/08

Installed by: Specialized Septic

Operation Permit by: Maria Watson R.S. date 1/28/09

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK