Pier Marina
4628-50-7259

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Pier Landing Restaurant DATE 5-16-79 PERMIT NO. 158

PHONE: Business _____ Home _____


LOCATION 150N T.L. at Pier Rest. at end of Rd. on Rt. _____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (✓) Other 20 Seat Restaurant

No. Bedrooms — No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes (✓) No ( )
Lot Area Existing

Character & Porosity of Soil clay loam
Percolation Rate 80 mpi +
Topography 4-6%
Depth to Water Table 6' to 8'
Rock or other impervious formations none obs.



Plot of System

1000gal pump tank
Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 1800 Linear Ft. 600
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Ray Berry

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 5-16-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold