IREDELL COUNTY HEALTH DEPARTMENT STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 162256 PIN # 4628523826 DATE June 25, 2010

OWNER or APPLICANT John & Harriet Kline PHONE: Business 704-662-8625 S&ME Home:

OWNER or APPLICANT ADDRESS 121 Codfish Hill Road Bethel NC 06801

LOCATION / DIRECTIONS 150 W TR Pinnacle Shores Th Plantation on Rt. Easement: Pinnacle Shores Rd. on Left

SUBDIVISION Pinnacle Shores BLOCK / SECTION LOT # 67 LOT AREA DESIGN FLOW 600 gpd L.T.A.R. .39 gpd/ft²

Septic Tank 1500 Gallons: STB 338 Date 7/5/11

Pump Tank 1500 Gallons: PT 471 Date 7/5/11

Pump Make Myers Model P102 Serial #

Nitrification Field No Fields 1 No Lines 6 Linear Feet 502

Trench Width 36" Max. Trench Bottom Depth 30" Gravel Depth ★

☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

System Description: 25% Reduction PM & Drop Boxes

Repair System Description: LP PPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 5 ☐ Business No. Persons ☐ Other No. Employees ☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions

System & Repair in Septic Easement
9/15/2011 Checked-Tanks

Comments / Conditions 12/5/11 Lines Checked
1-40', 3 @ 120' (1 line split into 2-60')
Used ADS36

INITIAL SITE SKETCH

★ If infiltrator used place 3" washed stone in first 4' of trench to slow flow

See Approved plan from S&ME

The proposed / existing Swimming Pool addition does not appear to impact the existing septic system.
**NOTE: See Site sketch for Pool Site
Mark Robertson REHS
Date: 10/21/2011
ICHD-Environmental Health Division

AS BUILT SKETCH

4/27/12 Set 2ft. pressure
Checked Eject & Alarm

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat-valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 7-14-10 Installed by:

Improvement Permit by: Andy Melville Date 6-25-10 Operation Permit by: Mark Robertson Date: 4/27

Authorization to Construct by: REHS Date 5-19-11 Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Ap.