Maria Dotson

From: Greg Handzlik <ghandzlik@archadeckofcharlotte.com>
Sent: Tuesday, March 25, 2014 9:41 AM
To: Maria Dotson
Subject: Re: 149 Plantation

Hello Maria,

I hope you are having a great day. We are going to change the way we build the porch extension in the area of the septic and pump. The plan is to use the existing columns and cantilever the extension out 3 feet. Thus eliminating the two columns that would have been within 5 feet of the septic tank. Please feel free to call or email if you need any additional information.

Please let me know when you pass along your approval.

Thanks,

Greg Handzlik
Archadeck
704-430-7746

Sent from my iPhone

On Mar 25, 2014, at 8:54 AM, "Maria Dotson" <MDotson@co.iredell.nc.us> wrote:

> Greg:
> Please send me the revisions to your structure.
> Thanks,
> Maria Dotson