IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 165887/168/169 PIN # 4628 53 1109 DATE April 8, 2011

OWNER or APPLICANT ~~Joseph Kenney~~ / James Kaptis PHONE: Business 704-904-5282 Home:

Kenneth Beaver

OWNER or APPLICANT ADDRESS 2319 Tattersall Dr. Charlotte NC

LOCATION / DIRECTIONS Hwy 150 West TR Pinnacle Shores Th Plantation Dr. on right at end

SUBDIVISION Pinnacle Shores BLOCK / SECTION LOT # 70 LOT AREA .717 Ac. DESIGN FLOW 480 gpd L.T.A.R. .275 gpd/ft², 25 Repair

Septic Tank	1000	Gallons: STB	312	Date	7-8-11	☒ New System	☐ Repair	☐ Expansion System	Type I II III (IV) V VI
Pump Tank	1000	Gallons: PT	27	Date	12-11	System Description:	LP PPBPS		
Pump Make	Myers	Model	ME 50	Serial #		Repair System Description:	LP PPBPS		
Nitrification Field	No Fields 1	No Lines 4	Linear Feet 300			Maintenance Agreement Required	☒ YES	☐ NO	
Trench Width	24"	Max. Trench Bottom Depth	36"	Gravel Depth	NA	☐ GRAVITY	☒ PRESSURE		

☒ Residence	No. Bedrooms 4	Water Supply		
☐ Business	No. Persons	☐ Private		
☐ Other	No. Employees	☐ Public		
☐ Slab	☒ Crawl Space	☒ Community		
☒ Basement w/plumbing ★	☐ Basement w/o plumbing			

Comments / Conditions

- Maintain 25' setback from basement to lowest repair line
- Driveway must be located w/in 10' of side PL

Comments / Conditions

★ Partial basement only 8/17/11

Floor plans & Site plans reviewed & in Compliance with original plans.

★Note! Drive on other side, must hug PL.

INITIAL SITE SKETCH

3/16" hole drilled

See Plan from Michael Athanas & Associates Approved by ICHD

AS BUILT SKETCH

8/18/11 Checked tanks

9/11/12 Checked lines, ~ 7ft to GVB from PL

The proposed / existing Inground Pool addition does not appear to impact the existing septic system.

**NOTE: Must stay at least 15ft from Septic

Maria Dotson R.S.

Date: 2-6-2012

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 4-11-11

Improvement Permit by: Judy McKillip REHS Date 4-8-11

Authorization to Construct by: Maria H. Dotson RS Date 8/17/11

Installed by: R&H

Operation Permit by: Maria H. Dotson RS Date: 5/8/2012

Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant