DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 25 Pinnacle Shores PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-9	gr brn sl/scl	fr					PS .3 @ L34"
		9-22	SAB RC	fr sp					
		22-34	wk fsab RCL	fr sss sp	few common mid SAP				
		34-48	wk fsab grad	SAP/ld w/ common mid SAP/WK.					
2		0-5	gr brn sil	fr					
		5-16	SAB RC	fr sp					
		16-22	WK SAP			(4)			
		22-26	SAB RCL						
		26+	hard WR						
3		0-5	gr brn sil						PS .3 @ L44"
		5-18	SAB RC	fr sp					
		18-44	mwk sab grad	fr sss sp	few common mid SAP				
		44-48	(BC) yr ch SAP/CL	w/ common mid SAP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

EPARTMENT OF ENVIRONMENT,
EALTH, & NATURAL RESOURCES
IVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: CKI OWNER: ___ AGENT: ___ PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 6/21/95
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: lot 25 Pennock Shores
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-7	gr- sl	vfr					.3
		7-34	msbk- heavy cl	fi					
		34-48	wkmk cl	fr					
2		0-4	gr sl	fr					.3
		4-14	SSAB C	fi					
		14-31	wf cl	fr					
		31-49	wf l	fr					
3									
4									
5									

AVAILABLE SPACE (.1945) ____ SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: ____
EVALUATED BY: ____ OTHER(S) PRESENT: ____
COMMENTS: ____