IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 073477 PIN# 4628 62 3836 DATE 5/11/98

OWNER OR CONTRACTOR ~~E~~ STEVE SMITH PHONE: Business _____ Home 892-9109

ADDRESS 115 SPRING WOOD LN MOORESVILLE 28117

LOCATION 150 W TR Pinnacle Shores Dr on (L) across from Emerald Ct.

SUBDIVISION Pinnacle Shores BLOCK / SECTION 1 LOT 57 LOT AREA 1 +/- .8AC SITE CLASS. RS DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 794 Date 7-31-01
Pump Tank: 1000 Gallons; PT 27 Date 7-27-01
Pump Make: Gould Model WE0-112855 Serial No. S0248143285
Nitrification Field: No Fields 1 Square Feet ~~X 532~~ Linear Feet ~~X 266~~
No Lines ~~X 4~~ Trench Width ~~2'~~ 3' Max Trench Bottom Depth ~~X 40"~~ Gravel Depth SAND.

[X] New System [ ] Repair System Type: I, II, III, (IV) V, VI
System Description: Pressure 16" PPBS
Repair System Description: SAME
Maintenance Agreement Required: [ ] Yes [ ] No

[X] House/Mod. Home No. Bedrooms 4
[ ] Mobile Home No. Bathrooms 4
[ ] Business No. Employees ____
[ ] Other ____

Water Supply: [ ] Individual [ ] Public [X] Community

[ ] Slab [X] Crawl Space [ ] Basement w/plumbing [ ] Basement wo/plumbing

Comments:/Conditions: Lot upgraded to PS after Saprolite Eval Pits w/T Jacobs CPSS.

Comments:/Conditions:

INITIAL SITE SKETCH

(1) Do not attempt installation before reading T. Jacobs Site Plan and fully understanding contents.

(2) Special attention required in Plan for protection of the 2 drainfields. This permit requires all the provisions be followed exactly.

(3) Surface water diversion required as described in T. Jacobs Plan.

(4) PLAN MODIFIED 1/17/01 caf

AS BUILT SKETCH

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: ~~X~~ Cindy A Ewin date 5/14/98 Installed by: F T Ewin

Improvement Permit by: Wesley Sparks RS. date 5/11/98 Operation Permit by: Wesley Sparks RS date 4/16/02

Authorization to Construct by: Wesley Sparks RS. date 5/11/98 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD