9:30

IREDELL COUNTY HEALTH DEPARTMENT

AUTHORIZATION TO CONSTRUCT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / ~~CERTIFICATE OF COMPLETION~~ / OPERATION PERMIT / EXISTING SYSTEM INSPECT

PROPERTY DESCRIPTION NO. 066756 DATE 5/13/97 TAX MAP NO. 4628625259 Watershed: ☑ Yes ☐

OWNER OR CONTRACTOR DAVID HUNT PHONE: Business Home

ADDRESS 152 EMILY DR. ADVANCE NC 27006

LOCATION 150W TR PINNACLE SHORES - TR SHELTER COVE - ON CORNER ON LT

SUBDIVISION PINNACLE SHORES BLOCK / SECTION I LOT 32 LOT AREA 1.77AC SITE CLASS. PS DESIGN FLOW 480GPD L.T.A.R. ~.36GPD/FT²

Septic Tank: 1000 Gallons; STB 794 Date 12/5/97

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 530 Linear Feet 265

No Lines 7 Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: GRAVITY PANEL

Repair System Description: PUMP PANEL

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms 4

☐ Business No. Employees

☐ Other

☐ Slab ☐ Crawl Space ☑ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Community ☐ Public

Comments: INSTALLER OF SEPTIC SYSTEM NEEDS TO HAVE CONSULTATIVE VISIT WITH HEALTH DEPARTMENT BEFORE INSTALLATION.

Comments: MAY BE PUMP SYSTEM IF GRAVITY CANNOT BE ACHIEVED.

INITIAL SITE SKETCH

SEE ATTACHED DRAWING.

AS BUILT SKETCH

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Signed:

Improvement Permit by: C Bldy Treen date 5/13/97

~~Existing System Inspection by:~~ INFORMATION ONLY C Bldy Treen date 5/13/97

Installed by: ORBESON

Certificate of Completion by: date

Operation Permit by: C K Treen RS date 2/10/98

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD