IREDELL COUNTY HEALTH DEPARTMENT

500

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECT

PERMIT# 23331/7940 73 PIN# 4628 63 0529 (766661) Permit # DATE 5/15/00

OWNER OR CONTRACTOR Robert Cutler PHONE: Business Home 892-6772

ADDRESS 105 Harbor Pte Ct. Cornelius, NC. 28031

LOCATION 150 W - TR Pinnacle Shores Dr. to end off Cul de sac

SUBDIVISION Pinnacle Shores BLOCK / SECTION 1 LOT 50 LOT AREA 1.14AC SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 1012 Date 7-15-00
Pump Tank: 1000 Gallons; PT 17 Date 7-25-00
Pump Make: Goulds Model 1/3HP Serial No.
Nitrification Field: No Fields 1 Square Feet 840 Linear Feet 280
No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" ~~Gravel Depth~~ SAND

[X] New System [ ] Repair System Type: I, II, III, IV, V, VI
System Description: LP - 16" PPBS
Repair System Description: SAME
Maintenance Agreement Required: [X] Yes [ ] No

[X] House/Mod. Home No. Bedrooms 4
[ ] Mobile Home No. Bathrooms 4
[ ] Business No. Employees
[ ] Other
[ ] Slab [ ] Crawl Space [X] Basement w/plumbing [ ] Basement wo/plumbing

Water Supply: [ ] Individual [ ] Public [X] Community

Comments:/Conditions: For Layout + Specifications refer to Toney Jacobs Plan dated 5/2/00 - Do not attempt installation before reading Plans + Specs for this site.

Comments:/Conditions:

INITIAL SITE SKETCH

Refer to Site Plan in Plans and Specifications

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit -- not to exceed sixty months.

Signed: X Toney C Jacobs LPSS (Agent) date 5/14/00

Improvement Permit by: Wesley Sparks RS. date 5/15/00

Authorization to Construct by: Wesley Sparks RS date 5/15/00

Installed by: Forest Shuford

Operation Permit by: Marie H. Watson RS date 1/16/2001

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK