IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bob Underwood DATE 11-29-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 S To Troutman T.R. 1303 - T.R. 1321 T.R. on 1405 House Near Point on R. _____ S. R. No. _____

SUBDIVISION NAME Allendale Point LOT NO. 14 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area Approx 20000 sq'

Character & Porosity of Soil Red Clay loam
Percolation Rate —
Topography Slope to Lake
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10'
Water Supply: Individual (✓)
Public ( )

Installed by Raymond Adams

IMPROVEMENTS PERMIT BY Andrew E. Causey

COMMENTS: Back of tank is Dep. Divert Surface Water away from lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11-29-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold