THIS PERMIT REPLACES PREVIOUSLY ISSUED PERMIT

CI

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 71897 PIN# 4628 69 6673 DATE 11-14-01

OWNER OR CONTRACTOR DEBRAH RIFFLE PHONE: Business _____ Home 664-3165

ADDRESS 101 ROLLING MILL RD OLD HICKORY TENN

LOCATION MORRISON FARM, (B) ALLENDALE CIRCLE, 4th LOT PAST CURVE

SUBDIVISION ALLENDALE PT BLOCK / SECTION _____ LOT 19 LOT AREA .52 LAKE LOT + SLIGHTLY SITE CLASS PS DESIGN FLOW 480 L.T.A.R. 1.3

Septic Tank: 1000 Gallons: STB 794 Date 8-29-01

Pump Tank: 1000 Gallons: PP 27 Date 9-22-01

Pump Make: GOULDS Model WE1012H Serial No 502995191

Nitrification Field: No Fields 1 Square Feet 68=1600 Linear Feet 270'

No Lines 6x45 Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth N/A

[X] New System [ ] Repair System Type: I II (III) IV V VI

System Description: PUMP PANEL

Repair System Description: LP PANEL

Maintenance Agreement Required: [ ] Yes [X] No

[X] House/Mod. Home [ ] Mobile Home [ ] Business [ ] Other

No. Bedrooms 4 No. Bathrooms 3½ No. Employees _____

[ ] Slab [ ] Crawl Space [X] Basement w/plumbing [ ] Basement wo/plumbing

Water Supply: [X] Individual [ ] Public [ ] Community WELL

Comments/Conditions:

Comments/Condition: (1) ZABEL FILTER + MARKER (2) CHECKED DRAINLINES (3) NEEDS ELECTRICAL, PRESSURE, REGISTER OF DEEDS + CHECK SUPPLY LINE (3) CHECKED SUPPLY LINE, ELECTRICAL, & GOT REG OF DEEDS PLAT (4) NEEDS PRESSURE

INITIAL SITE SKETCH

SEE ATTACHED SHEET FOR:

LAYOUT, ST, PT, PRESSURE LINE + DISPOSAL FIELD

AS BUILT SKETCH

PRESSURE CHECKED SYSTEM WORKS OK! CC 12-6-01

Permit can be suspended or revoked if any false information is supplied toward securing the permit, any unauthorized changes are made to the site, any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit - not to exceed sixty months.

Signed: _____ date 11/29/01

Improvement Permit by: _____ RS date 11-14-01

Authorization to Construct by: _____ RS date 11-14-01

Installed by: PERRY LANEY

Operation Permit by: _____ RS date 12-6-01

Existing System Inspection by: _____ date _____

HEALTH DEPT COPY WHITE OWNER COPY (FINAL) YELLOW OWNER COPY (INITIAL) PINK