DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: CRI OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 8/25/95
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: Lot 10, Pinnacle Shoals
WATER SUPPLY: On-Site Well ___ Comm. Well ✓ Public ___ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	~20%	0-20	msl sbk R cl	fr, fi, ss, sp					.3
		20-48	wk sbk R/pr l w/ few mod stp	fr					
2	~15-20%	0-4	prism/sbk cl	fr, ss, sp					.3
		4-17	sbk R cl	fi, s, p					
		17-41	R cl Dark common Mn conc	fr, ss, sp					
3	~10%	0-4	lm cl	fr					.3
		4-20	R cl	fi, s, p					
		20-43	msbk R sil-cl w/ mod stp	ss, sp, p					
4									
5									

AVAILABLE SPACE (.1945) ____ SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: ____
EVALUATED BY: ____ OTHER(S) PRESENT: ____
COMMENTS: ____