IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 130.00 Paid MOORESVILLE 704-664-5281 11:15

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 106666 PIN# 4628-80-2618

OWNER OR CONTRACTOR G.M. Helms Const. / Michael Waters PHONE: Business 704-895-9000 Home DATE 5/15/02

ADDRESS 18515 Statesville Rd Cornelius NC 28031

LOCATION 150 W JR Indiga, at end

SUBDIVISION Pinnacle Shores BLOCK / SECTION 2 LOT 14 LOT AREA .672 Ac. SITE CLASS PS DESIGN FLOW 480 L.T.A.R. 0.5

Septic Tank: 1000 Gallons: STB 312 Date 10-8-02

Pump Tank: 1000 Gallons: PT 283 Date 9-24-02

Pump Make: Myers Model P102 Serial No.

Nitrification Field: No. Fields 1 Square Feet 1200 Linear Feet 400

No. Lines 4 @ 100' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth —

☒ New System ☐ Repair System Type: I, II, (III), IV, V, VI

System Description: Press. Man. 25% Red.

Repair System Description: LP Panel Block

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Bathrooms 3½ No. Employees

Water Supply: ☐ Individual ☐ Public ~~☒ Community~~

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: Tanks 50'+ from lake
Tanks & lines Checked 11/15/02
Press, electrical & alarm 1/10/03

INITIAL SITE SKETCH

Installed E Z Flow Drainfield

Long Creek

Repair

Repair

old Road Bed

Lot 10

Comments/Conditions: ~~Filter not installed yet~~

AS BUILT SKETCH

50'

House

water Line

Lot 13

Lot 12

Septic & Basement

Lake

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 5-20-02

Improvement Permit by: [signature] RS date 5/15/02

Authorization to Construct by: [signature] RS date 5/15/02

Installed by: R & H

Operation Permit by: Marion H. Dotson date 1/10/03

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK