IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OW OR CONTRACTOR F. J. Mullally DATE 5-30-80 PERMIT NO. 150

PHC Business Home

LOCATION 150W TR 1438 ~.2 mile on left

S. R. No.

SUBDIVISION NAME Lake Norman LOT NO. 317 SECTION OR BLOCK NO. 11

House X Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (X)

Auto. Dishwasher Yes (X) No ( )

Auto. Wash. Machine Yes (X) No ( )

X Site Suitable Yes ( ) No ( )

Lot Area .9 acre ±

Character & Porosity of Soil tight Sandy parent Material w/ 2-10% stone


Percolation Rate 120-240 mpi

Topography 8%

Depth to Water Table unknown

Rock or other impervious formations NONE observed

___ Basement with Plumbing _X_ Basement without Plumbing ___ No Basement



Size of Tank 1000 Gals.

Nitrification Field: 100 linear ft

No. of Lines 2 rows of 2 pipes Sq. Ft. ___ Linear Ft. ___

Depth of Stone in Lines

Water Supply: Individual (X) Public ( )

Installed by F. J. Cain

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Fred Clemmer + David R Henson

COMMENTS: *50% good on house site - any Repair to be done on lease land adjacent to Lot; see attached lease Agreement

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 5-30-80

EXISTING SYSTEM CHECKED BY: ___ DATE ___

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold