IREDELL COUNTY HEALTH DEPARTMENT 4628 80 8634

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR H. C. Roberts DATE 9-12-78 PERMIT NO. 220

PHONE: Business _____ Home _____

LOCATION 150W TR on 1438 2nd Drive on right

SUBDIVISION NAME Lake Norman LOT NO. 315 SECTION OR BLOCK NO. 11 S. R. No. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 3/4 acre

Character & Porosity of Soil Clay loam
Percolation Rate 60 min/in
Topography 15% Slope
Depth to Water Table 61"+ 8"
Rock or other impervious formations None 41" Rock in Tank Hole



Size of Tank 500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft 200 Linear Ft. 90
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by E J Ervin

IMPROVEMENTS PERMIT BY _____

COMMENTS: Bottom of ditch very rought Poor workman ship on drain line

CERTIFICATE OF COMPLETION BY John Houston DATE 9-12-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold