IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Blanche Lyons DATE 10-29-95 PERMIT NO. _____

PHONE: Business _____ Home 919-299-8435


LOCATION 150 west TR on 1438 on right Just before end of Road S. R. No. 1438

SUBDIVISION NAME Lake Norman LOT NO. 297 SECTION OR BLOCK NO. 11

House ( ) Mobile Home ( ) Business ( ) Other Double Wide Mobile Home

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	
Auto. Dishwasher	Yes ( )	No (X)	Percolation Rate	
Auto. Wash. Machine	Yes (X)	No ( )	Topography	EXISTING
Site Suitable	Yes (X)	No ( )	Depth to Water Table	
Lot Area 3/4 acre			Rock or other impervious formations	SYSTEM



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. ~~562~~ Linear Ft. 225
Depth of Stone in Lines 10"

Water Supply: Individual (X)
Public ( )

Installed by Cline & Gillelan (Catawba Co.)
1967

IMPROVEMENTS PERMIT BY _____

COMMENTS: replacing single wide mobile Home with double wide. System is adequate to take care of Home.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-29-95

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold