IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 375.00 Paid MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 109051 PIN# 4628 81 6684 DATE 2/19/03

OWNER OR CONTRACTOR Trevor P Ashline PHONE: Business Church Court, 664-2845 Home

ADDRESS 3028 Westwood Drive Rock Hill, SC. 29731

LOCATION 150 W. TR Waddell Rd TR Clownhill Rd., lot on l at cul de sac, 2ND drive on (L)

SUBDIVISION CL+T BLOCK / SECTION 11 LOT 293 LOT AREA .9 AC SITE CLASS. DESIGN FLOW L.T.A.R.

Septic Tank: 1000 Gallons; STB 825 Date 9/14/03
Pump Tank: 1000 Gallons; PT 302 Date 11/5/03
Pump Make: Goulds Model WE1512 HN Serial No. 7/23/03
Nitrification Field: No Fields 1 Square Feet 500 Linear Feet 696
No Lines 8 Trench Width 18" Max Trench Bottom Depth 17" HIGH SIDE Gravel Depth 9"

[X] New System [ ] Repair System Type: I, II, III, (IV) V, VI
System Description: Pressure - LPP
Repair System Description: < 1983
Maintenance Agreement Required: [X] Yes [ ] No

[X] House/Mod. Home No. Bedrooms 4
[ ] Mobile Home No. Bathrooms 4
[ ] Business No. Employees
[ ] Other
[ ] Slab [ ] Crawl Space [X] Basement w/plumbing [ ] Basement wo/plumbing

Water Supply: [X] Individual [ ] Public [ ] Community

Comments:/Conditions: DO NOT ATTEMPT INSTALLATION BEFORE & WITHOUT (1) CONFERENCE WITH ICH D.- ENVIR. HEAL (2) COMPLETE LOW PRESSURE PIPE SYSTEM PLAN FROM TONEY C JACOBS + ASSOC, INC

Comments:/Conditions:

INITIAL SITE SKETCH

(3) MAY USE CENTER BUNDLE OF EZ FLOW IN LIEU OF GRAVEL

(4) SMALL CHECK VALVE REQUIRED ON EACH SUPPLY LINE - AFTER VALVE BOX

SEE PLAN

LOW PRESSURE PIPE PLAN BY TONEY JACOBS, L.S.S.

(5) CHECK VALVE IS REQUIRED BETWEEN PUMP AND THREADED PVC UNION INSIDE PUMP TANK.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.


Signed: Joshua Oostsky date 2/21/03 Installed by: Joe Perkins

Improvement Permit by: Wesley Sparks RS date 2/19/03 Operation Permit by: Wesley Sparks RS date 6/4/04

Authorization to Construct by: Wesley Sparks RS date 2/19/03 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

C2	383.46'	S 65° 26' 44" W	143.65'	144.50'



R AS FIELD LOCATED ON 8/14/02.
F LAKE NORMAN WAS 754.80.
NE IS PARTIALLY IMPROVED WITH

PIER #8157

5/8" REBAR SET

EXISTING 1/2" REBAR

EXISTING 5/8" REBAR

FUTURE HOUSE

LOT 293

LOT 291
GLEN L. RHOI
wife JEANNE P.
DEED BK. 1120

Sr. and
IGHT
. 636

METER POLE

Pipe 30" minimum DEPTH - UNDER Drive

Any drain in RUNNING WATER must be 25' from lowest line

3" SCH 40 PVC

CENTRAL VALVE BOX (SEE DETAIL)

2" SCH 40 PVC

96' blue
96' white
96' red
96' blue
96' yellow
BUILDING SETBACK LINES
96' white
70' red
58' yellow

5/8" REBAR SET

TIE LINE L15

Proposed well site

Turn-up

GRAVEL DRIVE

WELL

EXISTING BENT 1" REBAR

1¼" SCH 40 PVC SLEEVED IN 4" CORRUGATED DRAIN PIPE

CLOVERHILL ROAD

60'

50' DRIVE

C1

C2

L1 L2 L3 L4 L5 L6 L7 L8 L9 L10 L11 L12 L13 L14

15'

50'

51.7'

58.1'

136.06'

N 4° 15' 56" W 230.50'

S 14° 11' 00" E

15.7'

330'

(a) Trench for supply lines provided w/ Buyer
(b) Supply line beside house dug per theirs by Builder
(c) Valve Box common drawing Cope to flush up with ground surface

1"=30'

I, Michael R. Bowder
this plat was drawn
an actual field surve
my direct supervisio
boundaries shown a
record information r
that the actual r
exceeds 1:10,00
plat represent
of land. With
nature, see
this the