DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: MARVIN WILLIAM MCCOMBS
ADDRESS: 143 POINT OF VIEW DRIVE MOORESVILLE NC 28117
PROPOSED FACILITY: 4BR
PROPOSED DESIGN FLOW (.1949): 480
LOCATION OF SITE: 143 POINT OF VIEW DRIVE MOORESVILLE
APPLICATION DATE
DATE EVALUATED: 4/13
PROPERTY SIZE:
PROPERTY RECORDED:

WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 18%	0-9	FILL						
		9-20	WMSBK REG C	F SS SP					
		20-28	WFSBK REG CL	FR SS SP	FEW COMMON SAP	28"	PS	—	PS .35
		28-60	MASS L	FR SS SP SEXP					
2	L 22%	0-13	MFSBK REG C	F SS SP					
		13-23	WFSBK REG CL	FR SS SP		23"	PS	—	PS .4
		23-40	MASS L	FR SS SP					
		40-60	MASS SL	VFR SS SP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Accepted	Accepted w/(SI)
Site LTAR	0.35	0.35

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. Ashley Rollans, LSS
OTHER(S) PRESENT:

COMMENTS: