P.O. Box 288
STATESVILLE, N.C.

4994

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR HARRY TSUMAS JR. DATE 7-14-86, PERMIT NO.

PHONE: Business Home

LOCATION Morrison Farm Rd - go to end + ground to backside & circle + take dirt st. down to point (Morrison Point).

SUBDIVISION NAME S. R. No.


LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other Addition w/ 2 bedrooms + 1 bath.

No. Bedrooms 4 No. Bathrooms 3.5

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Prev. Suitable.
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate .5 gal/sq. ft.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2-8% Ø.F
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 10+
Lot Area Ample			Rock or other impervious formations none observed.

Basement with Plumbing Basement without Plumbing No Basement



Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 1
Sq. Ft. 220 Lingar Ft. 110
Depth of Stone in Lines 12" SAND.

Water Supply: Individual (✓)
Public ( )

T+T Panels (24") with 12" SAND UNDER PANELS.

Installed by Harry Tsumas JR + Al Fraley.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Old S.T. system abandoned - old well (2") abandoned & filled with concrete. Ground floor toilet connected to 440 gal. tank with ½ hrs. grinder pump inside tank. Washing machine connected to 75 gal. washer box with 16' of subsurface trench attached.

CERTIFICATE OF COMPLETION BY Steve Brown

EXISTING SYSTEM CHECKED BY: DATE 7-14-86.

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold