12475

## IREDELL COUNTY HEALTH DEPARTMENT

~~39333~~ ~~39333~~ 39333

### (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kent Shaw DATE 5-24-91 PERMIT NO. 3C-8-A-21

PHONE: Business _____ Home _____

LOCATION Morrison Farm Rd off State Park Rd Go to end bear left at Forks To back of circle TL 2nd Hse on left S. R. No. _____

SUBDIVISION NAME Morrison Point LOT NO. 21 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area Ample

Character & Porosity of Soil Prov Suitable
Percolation Rate 14
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations None

✓ Basement with Plumbing ___ Basement without Plumbing ___ No Basement

very Important To divert surface water around system




Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines _____
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public ( )

150' 16" T+J Panel

Installed by WCS Eytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Grinder Solids Sewage Pump is installed on lower level. Must meet Iredell Co Building Insp. Dept. Standards

CERTIFICATE OF COMPLETION BY F. C. Moore DATE 5-24-91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold