IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR L. Dan Kay Jr. DATE 9/20/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Perth Rd in Troutman - T.R. on 1321. Bear To L Past Pennsillin H. Rd. House on L - Near End. S. R. No. _____

SUBDIVISION NAME Morrison Point LOT NO. 20 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 – No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____


Character & Porosity of Soil _____

Percolation Rate _____

Topography _____

Depth to Water Table _____

Rock or other impervious formations _____



Plot of System

Existing

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 750 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Donald Lackey on 1/26/76

IMPROVEMENTS PERMIT BY _____

COMMENTS: Addition to Existing House. Sewage system appears to be working O.K. at this time

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 9/20/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold