IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR L. D. Kay DATE 1/26/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Pood Ck Rd. at Troutman, T.R. on 1321, Bear to left past Pennsville Point, house on left near end of road S. R. No. _____


SUBDIVISION NAME Morrison Point LOT NO. 20 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes ( )	No ( )	Topography	Slope to Lake
Site Suitable	Yes ( )	No ( )	Depth to Water Table	low
			Rock or other impervious formations	none observed

Lot Area 20,000sq'



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 15"

Water Supply: Individual (✓)
Public ( )

Installed by Donald Lucky

IMPROVEMENTS PERMIT BY _____

COMMENTS: Well is more than 50' from tank and lines

CERTIFICATE OF COMPLETION BY Andrew E. Caruso DATE 1/26/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold