IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 1 3C)

OWNER OR CONTRACTOR Paul T. Summerville DATE 10/16/79 PERMIT NO.

PHONE: Business Home

LOCATION 150 WTR 1438 TR 1450 ~Yadkin TR Hermance Drive At end on left S. R. No.

SUBDIVISION NAME Lake Norman LOT NO. 276 SECTION OR BLOCK NO. 11

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 1.28 acre


Character & Porosity of Soil Clay Loam
Percolation Rate 80 MPI
Topography 15-30%
Depth to Water Table 10+
Rock or other impervious formations None OBSERVED

Installed 1000 gal tank pump 1000 Gals.

Size of Tank

Nitrification Field:
No. of Lines 5 Linear Ft. 250
Sq. Ft. 750
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Richard Ab Leon Thom



Plot of System

IMPROVEMENTS PERMIT BY David Henson

COMMENTS: System never Approved
Gave Approval For House 2-23-

CERTIFICATE OF COMPLETION BY

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOC

Health Dept. Copy: White Inspection