4628910624

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bob warner DATE 4-13-98 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 150 w TR on 1438 1mi TR on Hwy 5th 3rd lot on right S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 255 SECTION OR BLOCK NO. 11


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area 3/4 acre

Character & Porosity of Soil sandy clay + Rock matter
Percolation Rate 100 min Rich 8 to 30 min/in
Topography 10% Slope
Depth to Water Table 10'+
Rock or other impervious formations Some heavy rock Formations in 20% of Lot



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by John Howie

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. L. Moore DATE 4-13-98

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold