4628916466

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Harold Dan Honeycutt DATE 6-23-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 150 W TR Waddell Rd. TR Hermance TR 2nd private access at end on left S. R. No. _____

SUBDIVISION NAME L.N. LOT NO. 270 SECTION OR BLOCK NO. 11

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 20000 ft²

Character & Porosity of Soil Clay


Percolation Rate 2.35

Topography 10-20% ↓↑

Depth to Water Table 4ft

Rock or other impervious formations none obs.

0 Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 1050 Linear Ft. 350

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Cain Construction Iredell Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY DK Hanson, RS DATE 6-23-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold