IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Joe Sutton DATE 2-6-78 PERMIT NO. 11

PHONE: Business _____ Home _____

LOCATION 150 w Iron Ore Rd Iron Ore Rd 1450 ½ mi rt. 2nd road

SUBDIVISION NAME Lake Norman LOT NO. 268 SECTION OR BLOCK NO. 11 S. R. No. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	( )	No	(✓)
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 3/4 acre

Character & Porosity of Soil Sandy Clay Loam
Percolation Rate 60 min/in
Topography 7 % Slope
Depth to Water Table 10'+
Rock or other impervious formations Parent Material



Plot of System

Size of Tank Existing 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16
Water Supply: Individual (✓)
Public ( )

Installed by E. J. Eaves

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Peter Hawkins DATE 2-8-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold