2 pm

10721

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William Turner DATE Nov. 16, '89 PERMIT NO 2N-3-A-260

PHONE: Business _____ Home _____

LOCATION 150 W. TR 1438 (Waddell) TR 1450 (Hormance) TR 1451 (Golden Pond) on left at end S. R. No. _____

SUBDIVISION NAME CL&T Lake Norman LOT NO. 260 SECTION OR BLOCK NO. 11

House (✓) Mobile Home ( ) Business ( ) Other Addition to structure (1 bedroom, bath & garage) w/ Add'n.

No. Bedrooms 3 No. Bathrooms _____

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Lot Area _____

Character & Porosity of Soil clay / pm trans.

Percolation Rate .2-.3

Topography 15-25% terraced

Depth to Water Table 3½'+

Rock or other impervious formations none obs. <3½'

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

1000 pump tank

Size of Tank Existing Gals.

Nitrification Field:


No. of Lines 3

Sq. Ft. _____ Linear Ft. 130' of

Depth of Stone in Lines 16" Top of

Water Supply: Individual (✓) panels

Public ( )



Plot of System

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Mike Slaughter

Pump specs: 13 gal/min. at Approx. 28' TDH

IMPROVEMENTS PERMIT BY Jamie R. Hamrick, R.S.

COMMENTS: Maximum trench bottom depth of 30". Use ONE 5/32" hole per panel (30 panels total) and 1¼" Sch 40 laterals through panels. Two feet of pressure head/ditch. Set Bull Run valve between existing tank and drainfield. Remove all parts of existing drainfield within 5' of proposed addition

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold